

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	4.24 – 8.2.1	DSH 0841A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Luminaire with fuse holder / fuse	<ul style="list-style-type: none"> - Entrance - Tool - Marking 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>On a luminaire with built-in fuse holder/fuse, is it permitted to touch live parts with the standard test finger during the substitution of the mentioned component?</p>			
Decision			
<p>Acceptable if the entrance can be made by using a tool only. Marking is not sufficient.</p>			
Explanatory notes			
<p>---</p>			