

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	4.8	DSH 0848A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Switches for luminaires	<ul style="list-style-type: none"> - Switches - 10000 cycles - EN 61058-1 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>The standard for switches for appliances (EN 61058-1) allows switches with different number of operating cycles. A common requirement should be applied for switches as components of luminaires.</p>			
Decision			
<p>The Group agrees to apply for switches for luminaires the requirements of switches for frequent operating cycles (10.000 cycles, see EN 61058-1, note of sub-clause 7.14). The requirements of EN 61347-2-11 are suitable for daylight sensors / presence sensors and temperature controls.</p>			
Explanatory notes			
