

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	4.11.3	DSH 0853A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Locking device for screws	<ul style="list-style-type: none"> - Locking device - Mechanical connections - Fixing screws 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>Screws which serve as electrical as well as mechanical connections shall be locked against loosening.</p> <p>1) Is it acceptable if only one of two fixing screws of a ballast is provided with a locking device?</p> <p>2) Is it acceptable if the ballast is fixed with only one screw (provided with a locking device), while the other side is fixed with tape?</p>			
Decision			
<p>1) Yes.</p> <p>2) Yes.</p>			
Explanatory notes			
<p>---</p>			