




OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	5.2.10	DSH 0882A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Cord anchorage	<ul style="list-style-type: none"> - External wiring - Cord anchorage - Precautions 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting

Question

Is the use of a locking cable tie (tie wrap) allowed as cord anchorage for external cable or cord? Is it also acceptable as cord anchorage for internal wiring (e.g. coming out of the luminaire) and if yes, is there any particular precaution that must be taken into account?



Decision

Not allowed for X attachment; acceptable for Y and Z attachments under the condition that all requirements are fulfilled.

Explanatory notes
