

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	Annex C	DSH 0931A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Self-ballasted lamps luminaires	<ul style="list-style-type: none"> - Abnormal condition - 240 hours - Self ballasted lamps 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting

Question

Is it in order to consider luminaires using lamps with integrated circuits, such as self-ballasted lamps, as luminaires for which there is no abnormal condition and the total test duration then becomes 240 hours (i.e. 10 times 24 cycles at normal operation as already stated in 12.3.1 item c)?

Decision

Yes.

Explanatory notes
