

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
EN 60598-2-13:2006/A2:2016	13.5 – 13.13	DSH 0949A	2019
Category			
LITE			
Subject	Keywords	Developed by	Approved at
Marking on ground recessed luminaire	<ul style="list-style-type: none"> - Ground recessed - Marking - IP rating 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>In clause 13.13 the following is stated: "Luminaires shall meet at least both IP 65 and IP 67 requirements." The luminaire is than tested accordingly, but how shall it be marked:</p> <ul style="list-style-type: none"> - With the both IP numbers? - With the highest IP number? - With the lowest IP number? 			
Decision			
Both IP numbers.			
Explanatory notes			
