

## OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
EN 60570:2003/A1:2018	General	DSH 0991A	2019
<b>Category</b>			
LITE			
Subject	Keywords	Developed by	Approved at
Openings for the adapters	<ul style="list-style-type: none"> <li>- Construction</li> <li>- Openings</li> <li>- Adapters</li> </ul>	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
<b>Question</b>			
<p>Is it acceptable to have an electrical supply track system with the openings for the adapters facing upwards?</p>			
<b>Decision</b>			
<p>Such a construction that is not on or in the floor can still comply with the standard.</p>			
<b>Explanatory notes</b>			
---			