

		LOVAG DECISION SHEET (LDS)		N°[LDS190]
				Pag. 1 of 1
References	Standard(s) (incl. year)	[IEC 61439-1: 2011]		Subclause(s): 10.11.5.4
	Subject	[Value and duration of the short-circuit current]	Submitted by: TECNALIA	Date: 31/05/2018 []
Question	The value of the prospective short-circuit current at a test voltage equal to 1,05 times the rated operational voltage...			
Analysis	We have not seen in IEC 61439-1 reference to tolerances on this voltage; what tolerance can be assumed to be applied on this voltage?			
Decision	Use tolerance of IEC 60947-1, -0 + 5% on test voltage of 1,05 rated operational voltage.			
Date: [19/06/2018]		Prepared by: [Tecnalia]		Approved by: [LOVAG Technical Committee 2018-06-19]